

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

June 2, 2004

DEL ZOTTO PRODUCTS INC DUANE PIONK 1900 COUNTY RD.1 WRENSHALL MN 55797

Re: Description: SEWAGE TANKS, CONCRETE Manufacturer: DEL ZOTTO PRODUCTS INC Product Name: SEPTIC, HOLDING OR PUMP

Model Number(s): 2000

(48" L.L., 41.1 GAL/IN., 48" MAX. DEPTH OF BURY, 847 G.P.D. WHEN USED AS A

SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL

WASTEWATER)

Product File No: 20040276

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent
 quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220
 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- When this product is in installed in a POWTS in accordance with the manufacturer's recommendations and per the product approval, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.
- All interior concrete surfaces above the lowest liquid level of this product must have a protected coating that will
 inhibit the deterioration of the concrete due to internal environmental effects or the concrete used to construct
 this product must have a water cement ratio not exceeding 0.45.

A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.

A copy of the approved plans and/or specifications is enclosed.

SBD-10564-E (N.10/97) File Ref: 04027601.DOC

DEL ZOTTO PRODUCTS INC Page 2 June 2, 2004

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wi.gov